

WestWood Liquid Technologies Ltd

31 Morris Road
Nutfield Industrial Estate
Poole
Dorset BH17 0GG



Tel: 0800 8085 480

e-mail: technical@westwood-uk.com

website: www.westwood-uk.com

Agrément Certificate

20/5838

Product Sheet 1 Issue 2

WESTWOOD POLYURETHANE WATERPROOFING SYSTEMS

WETHAN 275 SYSTEM

This Agrément Certificate Product Sheet⁽¹⁾ relates to the Wethan 275 System, consisting of a moisture triggered aliphatic polyurethane, for use as a glass fibre-reinforced waterproofing on flat roofs with limited access.

(1) Hereinafter referred to as 'Certificate'.

The assessment includes

Product factors:

- compliance with Building Regulations
- compliance with additional regulatory or non-regulatory information where applicable
- evaluation against technical specifications
- assessment criteria and technical investigations
- uses and design considerations

Process factors:

- compliance with Scheme requirements
- installation, delivery, handling and storage
- production and quality controls
- maintenance and repair

Ongoing contractual Scheme elements†:

- regular assessment of production
- formal 3-yearly review



KEY FACTORS ASSESSED

- Section 1. Mechanical resistance and stability
- Section 2. Safety in case of fire
- Section 3. Hygiene, health and the environment
- Section 4. Safety and accessibility in use
- Section 5. Protection against noise
- Section 6. Energy economy and heat retention
- Section 7. Sustainable use of natural resources
- Section 8. Durability

The BBA has awarded this Certificate to the company named above for the system described herein. This system has been assessed by the BBA as being fit for its intended use provided it is installed, used and maintained as set out in this Certificate.

On behalf of the British Board of Agrément

Date of Second issue: 24 September 2025

Originally certified on 8 January 2021

Hardy Giesler
Chief Executive Officer

This BBA Agrément Certificate is issued under the BBA's Inspection Body accreditation to ISO/IEC 17020. Sections marked with † are not issued under accreditation.

The BBA is a UKAS accredited Inspection Body (No. 4345), Certification Body (No. 0113) and Testing Laboratory (No. 0357).

*Readers MUST check that this is the latest issue of this Agrément Certificate by either referring to the BBA website or contacting the BBA directly.
The Certificate should be read in full as it may be misleading to read clauses in isolation.*

Any photographs are for illustrative purposes only, do not constitute advice and should not be relied upon.

British Board of Agrément

1st Floor, Building 3, Hatters Lane
Croxley Park, Watford
Herts WD18 8YG

©2025

tel: 01923 665300
clientservices@bbacerts.co.uk
www.bbacerts.co.uk

SUMMARY OF ASSESSMENT AND COMPLIANCE

This section provides a summary of the assessment conclusions; readers should refer to the later sections of this Certificate for information about the assessments carried out.

Compliance with Regulations

Having assessed the key factors, the opinion of the BBA is that the Wethan 275 System, if installed, used and maintained in accordance with this Certificate, can satisfy or contribute to satisfying the relevant requirements of the following Building Regulations:



The Building Regulations 2010 (England and Wales) (as amended)

Requirement:	B4(2)	External fire spread
Comment:		On a suitable substructure, the system may enable a roof to be unrestricted by this Requirement. See section 2 of this Certificate.
Requirement:	C2(b)	Resistance to moisture
Comment:		The system will enable a roof to satisfy this Requirement. See section 3 of this Certificate.
Regulation:	7(1)	Materials and workmanship
Comment:		The system is acceptable. See sections 8 and 9 of this Certificate.



The Building (Scotland) Regulations 2004 (as amended)

Regulation:	8(1)(2)	Fitness and durability of materials and workmanship
Comment:		The use of the system satisfies this Regulation. See sections 8 and 9 of this Certificate.
Regulation:	9	Building standards – construction
Standard:	2.8	Spread from neighbouring buildings
Comment:		When applied to a suitable substructure, the system may enable a roof to be unrestricted by this Standard, with reference to clause 2.8.1 ⁽¹⁾⁽²⁾ . See section 2 of this Certificate.
Standard:	3.10	Precipitation
Comment:		The system will enable to roof to satisfy this Regulation, with reference to clauses 3.10.1 ⁽¹⁾⁽²⁾ and 3.10.7 ⁽¹⁾⁽²⁾ . See section 3 of this Certificate.
Standard:	7.1(a)	Statement of sustainability
Comment:		The system can contribute to satisfying the relevant requirements of Regulation 9, Standards 1 to 6, and therefore will contribute to a construction meeting at least a bronze level of sustainability as defined in this Standard.
Regulation:	12	Building standards – conversion
Comment:		Comments given for the system under Regulation 9, Standards 1 to 6, also apply to this Regulation, with reference to clause 0.12.1 ⁽¹⁾⁽²⁾ and Schedule 6 ⁽¹⁾⁽²⁾ .
		(1) Technical Handbook (Domestic).
		(2) Technical Handbook (Non-Domestic).



The Building Regulations (Northern Ireland) 2012 (as amended)

Regulation:	23(1)(a)(i)(ii)	Fitness of materials and workmanship
Comment:	(iii)(iv)(b)(i)	The system is acceptable. See sections 8 and 9 of this Certificate.

Regulation:	28(b)	Resistance to moisture and weather
Comment:		The system will enable a roof to satisfy this Regulation. See section 3 of this Certificate.
Regulation:	36(b)	External fire spread
Comment:		On a suitable substructure, the system may enable a roof to be unrestricted by this Regulation. See section 2 of this Certificate.

Additional Information

NHBC Standards 2025

In the opinion of the BBA, the Wethan 275 System, if installed, used and maintained in accordance with this Certificate, can satisfy or contribute to satisfying the relevant requirements in relation to *NHBC Standards*, Chapter 7.1 *Flat roofs, terraces and balconies*.

In addition, in the opinion of the BBA, the system, when installed and used in accordance with this Certificate, can satisfy or contribute to satisfying the relevant requirements in relation to *NHBC Standards for Conversions and Renovations*, taking account of other relevant guidance within the chapter and the suitability of the substrate to receive the system.

The *NHBC Standards* do not cover the refurbishment of existing roofs.

The opinion of the BBA does not amount to any endorsement or approval by NHBC and does not in any way guarantee that NHBC will approve such product / system as compliant with the NHBC Technical Requirements and Standards.

Fulfilment of Requirements

The BBA has judged the Wethan 275 System to be satisfactory for use as described in this Certificate. The system has been assessed for use as a glass fibre-reinforced waterproofing on flat roofs with limited access.

ASSESSMENT

Product description and intended use

The Certificate holder provided the following description for the system under assessment. The Wethan 275 System consists of:

- Wethan 275 — a one-part, moisture-triggered, aliphatic based polyurethane
- Wethan Metal Primer — a two-part primer for the treatment of previously untreated metal surfaces and for spot priming of areas of corroded metal after preparation
- Wethan 141 — a primer for concrete substrates
- Weplus 225 CSM Reinforcing Mat — a non-woven glass reinforcement mat
- Wethan Heavy Duty Flexitape — polyester faced butyl tape for reinforcement of metal substrate joints.

Ancillary Items

The Certificate holder recommends a proprietary carrier membrane for use over substrates with joints, such as insulation boards or plywood decking, and beneath the waterproofing system, but this material has not been assessed by the BBA and is outside the scope of this Certificate.

Applications

The system is intended for use on the following substrates:

- concrete (primed and unprimed)
- asphalt
- bituminous roofing membranes, including mineral surfaced
- galvanized steel
- non-mineralised bitumen roofing membranes on plywood
- liquid-applied bituminous roof coating
- aluminium paint
- polyisocyanurate (PIR) foam insulation boards in conjunction with a specified carrier membrane
- existing polyurethane roofs.

Definitions for products and applications inspected

The following terms have been defined for the purpose of this Certificate as:

- limited access roof — a roof subjected only to pedestrian traffic for maintenance of the roof covering, cleaning of gutters, etc
- flat roof — a roof having a minimum finished fall of 1:80
- pitched roof — a roof having a fall in excess of 1:6.

Product assessment – key factors

The system was assessed for the following key factors, and the outcome of the assessment is shown below. Conclusions relating to the Building Regulations apply to the whole of the UK unless otherwise stated.

1 Mechanical resistance and stability

Not applicable.

2 Safety in case of fire

Data were assessed for the following characteristic.

2.1 External fire spread

2.1.1 When tested to CEN/TS 1187 : 2012 Test 4 and classified to BS EN 13501-5 : 2016, the constructions given in Table 1 of this Certificate achieved B_{ROOF}(t4) for slopes below 10°.

Table 1 Tested constructions

Substrate	System 1	System 2
	6 mm calcium silicate board	6 mm calcium silicate board
Carrier membrane ⁽¹⁾	2.6 mm thick SBS modified bitumen roofing membrane	—
Waterproofing	0.8 mm Wethan 275, Weplus 225 CSM Reinforcing Mat, 0.7 mm Wethan 275	0.8 mm Wethan 275, Weplus 225 CSM Reinforcing Mat, 0.7 mm Wethan 275

(1) These components are outside the scope of this Certificate.

2.1.2 On the basis of data assessed, the constructions listed in Table 1 of this Certificate will be unrestricted by the documents supporting the national Building Regulations with respect to proximity to a relevant boundary. Restrictions may apply at compartment walls.

2.1.3 The classification and permissible areas of use of other specifications must be confirmed by reference to the requirements of the documents supporting the national Building Regulations.

3 Hygiene, health and the environment

Data were assessed for the following characteristics.

3.1 Weathertightness

3.1.1 Results of weathertightness tests are given in Table 2.

Table 2 Weathertightness

System assessed	Assessment method	Requirement	Result
Wethan 275 System	Watertightness to EOTA TR-003 : 2004	No leakage	Pass
	Water vapour diffusion-equivalent air layer thickness (s_d) to BS EN 1931 : 2000	Value achieved	2.82 m
Wethan 275 System - on concrete	Resistance to delamination to EOTA TR-004 : 2004	≥ 50 kPa	Pass

3.1.2 The resistance to delamination for other substrates covered by this Certificate was assessed based on test data of representative related products.

3.1.3 On the basis of data assessed, the system will adequately resist the passage of moisture to the inside of a building and enable a roof to comply with the requirements of the national Building Regulations.

3.1.4 The adhesion of the system is sufficient to resist the effects of wind suction, elevated temperature and thermal shock conditions likely to occur in practice.

3.1.5 The resistance to wind uplift for warm roofs will be dependent on the cohesive strength of the insulation and the method by which it is secured to the roof deck. This must be taken into account when selecting a suitable insulation material.

3.2 Resistance to mechanical damage

3.2.1 Results of resistance to mechanical damage tests are given in Table 3.

Table 3 Resistance to mechanical damage

System assessed	Assessment method	Requirement	Result
Wethan 275 System	Tensile strength to BS EN ISO 527-4 : 1997	Value achieved	
	Control		1144 N·(50 mm) ⁻¹
	Cured at 2°C		1018 N·(50 mm) ⁻¹
	Cured at 40°C		1118 N·(50 mm) ⁻¹
	Elongation to BS EN ISO 527-4 : 1997	Value achieved	
	Control		3.1%
Wethan 275 System - on steel	Cured at 2°C		3.6%
	Cured at 40°C		3.5%
	Resistance to dynamic indentation to EOTA TR-006 : 2004	Value achieved	
	Control, tested at 20°C		I ₄
	Control, tested at -30°C		I ₄
	Cured at 2°C, tested at 20°C		I ₄
Wethan 275 System - on concrete	Cured at 40°C, tested at 20°C		I ₄
	Resistance to static indentation to EOTA TR-007 : 2004	Value achieved	
	Control, tested at 23°C		L ₄
	Control, tested at 90°C		L ₄
Wethan 275 System - on concrete	Resistance to fatigue cycling to EOTA TR-008 : 2004 Control, 1000 cycles	Watertight and less than 75 mm delamination from the substrate	Pass
Wethan 275 System	Crack bridging capability to EOTA TR-013 : 2004	No ruptures or adhesion failure	Pass

3.2.2 The resistance to dynamic and static indentation on PIR was assessed using test data from a representative related system.

3.2.3 On the basis of data assessed, the system can accept, without damage, the limited foot traffic and light concentrated loads associated with installation and maintenance and the effects of minor movement likely to occur in practice, while remaining weathertight.

3.2.4 Where traffic in excess of the examples given in section 3.2.3 are envisaged, such as for maintenance of lift equipment, a walkway must be provided (for example, using concrete slabs supported on bearing pads). Reasonable care must be taken to avoid puncture by sharp objects of concentrated loads.

4 Safety and accessibility in use

Not applicable.

5 Protection against noise

Not applicable.

6 Energy economy and heat retention

Not applicable.

7 Sustainable use of natural resources

Not applicable.

8 Durability

8.1 The potential mechanisms for degradation and the known performance characteristics of the materials in the system were assessed.

8.2 Specific test data were assessed as given in Table 4.

Table 4 Durability

System assessed	Assessment method	Requirement	Result
Wethan 275 System - on concrete	Resistance to delamination to EOTA TR-004 : 2004	≥ 50 kPa	Pass
- on asphalt	Exposure to 60°C water for 180 days to EOTA TR-012 : 2004		Pass
Wethan 275 System	Tensile strength to BS EN ISO 527-4 : 1997	Value achieved	1502 N·(50 mm) ⁻¹
	Heat aged at 80°C for 200 days to EOTA TR-011 : 2004		1676 N·(50 mm) ⁻¹
	UV aged for 1000 MJ·m ⁻² to EOTA TR-010 : 2004		
	Elongation to BS EN ISO 527-4 : 1997	Value achieved	2.8%
	Heat aged at 80°C for 200 days to EOTA TR-011 : 2004		2.5%
	UV aged for 1000 MJ·m ⁻² to EOTA TR-010 : 2004		
Wethan 275 System - on steel	Resistance to dynamic indentation to EOTA TR-006 : 2004	Value achieved	
	Heat aged at 80°C for 200 days to EOTA TR-011 : 2004, tested at -30°C		I ₄
	UV aged for 1000 MJ·m ⁻² to EOTA TR-010 : 2004, tested at -10°C		I ₄
	Resistance to static indentation to EOTA TR-007 : 2004	Value achieved	
	Exposure to 60°C water for 180 days to EOTA TR-012 : 2004, tested at 23°C		L ₄
	Exposure to 60°C water for 180 days to EOTA TR-012 : 2004, tested at 90°C		L ₄
Wethan 275 System - on concrete	Resistance to fatigue cycling to EOTA TR-008 : 2004	Watertight and less than 75 mm delamination from the substrate	Pass
	Heat aged at 80°C for 100 days to EOTA TR-011 : 2004, 50 cycles		
Wethan 275 System	Crack bridging capability to EOTA TR-013 : 2004	No ruptures or adhesion failure	Pass
	Heat aged at 70°C for 91 days		

8.3 The resistance to delamination after ageing for other substrates covered by this Certificate was assessed based on test data of representative related products.

8.4 Service life

Under normal service conditions, the system will have a life in excess of 25 years, provided it is designed, installed and maintained in accordance with this Certificate and the Certificate holder's instructions.

PROCESS ASSESSMENT

Information provided by the Certificate holder was assessed for the following factors:

9 Design, installation, workmanship and maintenance

9.1 Design

9.1.1 The design process was assessed by the BBA and the following requirements apply in order to satisfy the performance specified in this Certificate.

9.1.2 Decks to which the system is to be applied must comply with the relevant requirements of BS 6229 : 2018 and, where appropriate, *NHBC Standards* 2025, Chapter 7.1.

9.1.3 For design purposes of flat roofs, twice the minimum finished fall must be assumed unless a detailed structural analysis of the roof is available, including overall and local deflection, direction of falls, etc.

9.1.4 The system must not be applied directly to, nor come into contact with, polystyrene insulation products.

9.1.5 Insulation materials to be used in conjunction with the system must be in accordance with the Certificate holder's instructions and must be either:

- as described in the relevant clauses of BS 6229 : 2018, or
- the subject of a current BBA Certificate and be used in accordance with, and within the limitations of, that Certificate.

9.2 Installation

9.2.1 Installation instructions provided by the Certificate holder were assessed and judged to be appropriate and adequate.

9.2.2 Installation of the system must be carried out in accordance with the relevant clauses of BS 8000-0 : 2014 and BS 8000-4 : 1989, the Certificate holder's instructions and this Certificate. Additional guidance is provided in Annex A of this Certificate.

9.2.3 The system components must be at a temperature of, or greater than, 10°C for airless spray applications. All components must be applied when the air and substrate temperatures are greater than 5°C. Special precautions may be necessary when temperatures exceed 35°C, and the Certificate holder's advice must be sought, but such advice is outside the scope of this Certificate.

9.2.4 Application must not take place when the relative humidity is in excess of 95%, or in fog. The temperature/humidity must be such that there is no risk of surface condensation occurring before or during application. The wind speed must be such that it does not interfere with the application or cause overspray. No attempt to spray must be made if the wind speed exceeds $6.7 \text{ m}\cdot\text{s}^{-1}$ (15 mph), unless precautions such as the use of wind barriers are taken.

9.2.5 Substrates on which the system is to be applied must be properly prepared in accordance with the Certificate holder's instructions.

9.2.6 Adhesion to substrates will depend on the condition and cleanness of the substrate. Substrates must be visibly dry, sound and free from loose materials or contamination (eg moss or algae). The surface must be prepared to remove loose or flaking materials, and the substrate must be visibly dry before application of the system.

9.2.7 Damaged areas of the substrate (eg blistered membrane) must be removed, replaced or repaired. Substrate defects (eg shallow-bottomed cracks and indentations) must be filled in accordance with the Certificate holder's instructions.

9.2.8 Deck surfaces must be free from sharp projections such as concrete nibs.

9.2.9 Gutters and outlets must be checked to ensure that they are, and remain, clear of all debris.

9.2.10 All points of potential weakness such as splits, cracks, joints and crazed surfaces must be additionally reinforced in accordance with the Certificate holder's instructions prior to application of the main system.

9.2.11 Priming requirements of the substrate must be checked and carried out in accordance with the Certificate holder's instructions.

9.2.12 Application can be by brush, roller or spray. Brush application is normally used only for small roof areas and, when used, for embedding Weplus 225 CSM Reinforcing Mat into the waterproofing at areas of detailing.

9.2.13 Only areas that can be applied to the full thickness before weather changes occur must be attempted.

9.2.14 The system must be applied at the coverage rate for a smooth texture substrate given in Table 5. The advice of the Certificate holder on coverage rates for intermediate, rough, porous and undulating substrates must be sought, but such advice is outside the scope of this Certificate.

Table 5 System coverage rates and finished thickness

Layer (unit)	Full reinforcement system
Base coat (l·m ⁻²)	1.0
Reinforcement	Weplus 225 CSM Reinforcing Mat
Top coat (l·m ⁻²)	1.0
Finished thickness (mm)	1.5

9.2.15 When using Weplus 225 CSM Reinforcing Mat, this is embedded in the first coat while the membrane is still wet. Once the first coat is partially cured the second coat is applied.

9.2.16 Random tests must be carried out on the finished coating surface by cutting out small areas to measure finished cured thickness. Test areas must be repaired after the sample is taken.

9.2.17 Detailing (eg upstands) must be carried out in accordance with the Certificate holder's instructions.

9.2.18 The NHBC requires that the system, once installed, is inspected in accordance with *NHBC Standards 2025*, Chapter 7.1, Clause 7.1.11, including undergoing an appropriate integrity test, where required. Any damage to the system must be repaired in accordance with section 9.4 of this Certificate and reinspected, in order to maintain system performance.

9.3 Workmanship

Practicability of installation was assessed by the BBA and on the basis of the Certificate holder's information. To achieve the performance described in this Certificate, installation of the system must be carried out by specialist roofing contractors trained and approved by the Certificate holder.

9.4 Maintenance and repair

9.4.1 Ongoing satisfactory performance of the system in use requires that it is suitably maintained. The guidance provided by the Certificate holder was assessed by the BBA and found to be appropriate and adequate.

9.4.2 The following requirements apply in order to satisfy the performance assessed in this Certificate:

9.4.2.1 The system must be the subject of six-monthly inspections and maintenance in accordance with BS 6229 : 2018, and the Certificate holder's recommendations, where relevant, to ensure continued satisfactory performance. These inspections must be carried out by a suitably experienced and competent individual to ensure continued satisfactory performance. This must include an examination of the condition of the roof finishes and ensure that drain outlets and gutters are kept clear and unblocked.

9.4.3 Minor damage can be repaired by cleaning back to the unweathered material and recoating the damaged area with the membrane at the appropriate application rate stated in Table 5 of this Certificate.

10 Manufacture

10.1 The production processes for the system have been assessed, and provide assurance that the quality controls are satisfactory according to the following factors:

10.1.1 The manufacturer has provided documented information on the materials, processes, testing and control factors.

10.1.2 The quality control operated over batches of incoming materials has been assessed and deemed appropriate and adequate.

10.1.3 The quality control procedures and product testing to be undertaken have been assessed and deemed appropriate and adequate.

10.1.4 The process for management of non-conformities has been assessed and deemed appropriate and adequate.

10.1.5 An audit of each production location was undertaken, and it was confirmed that the production process was in accordance with the documented process, and that equipment has been properly tested and calibrated.

† 10.2 The BBA has undertaken to review the above measures on a regular basis through a surveillance process, to verify that the specifications and quality control operated by the manufacturer are being maintained.

11 Delivery and site handling

11.1 The Certificate holder stated that the Wethan 275 liquid component is delivered to site in 5 or 15 litre tins bearing the system's name, batch number and the BBA logo incorporating the number of this Certificate.

11.2 Delivery and site handling must be performed in accordance with the Certificate holder's instructions and this Certificate, including:

11.2.1 The liquid component must be stored in a dry, shaded area, above freezing point and away from ignition sources.

† ANNEX A – SUPPLEMENTARY INFORMATION

Supporting information in this Annex is relevant to the system but has not formed part of the material assessed for the Certificate.

Construction (Design and Management) Regulations 2015

Construction (Design and Management) Regulations (Northern Ireland) 2016

Information in this Certificate may assist the client, designer (including Principal Designer) and contractor (including Principal Contractor) to address their obligations under these Regulations.

CLP Regulations

The Certificate holder has taken the responsibility of classifying and labelling the system components under the *GB CLP Regulation* and *CLP Regulation (EC) No 1272/2008 - classification, labelling and packaging of substances and mixtures*. Users must refer to the relevant Safety Data Sheet(s).

Additional information on installation

Installation should also be carried out to the appropriate clauses in Liquid Roofing and Waterproofing Association (LRWA) Note 7 – *Specifier Guidance for Flat Roof Falls*.

Bibliography

BS 6229 : 2018 *Flat roofs with continuously supported flexible waterproof coverings — Code of practice*

BS 8000-0 : 2014 *Workmanship on construction sites — Introduction and general principles*

BS 8000-4 : 1989 *Workmanship on building sites — Code of practice for waterproofing*

BS EN 1931 : 2000 *Flexible sheets for waterproofing — Bitumen, plastic and rubber sheets for roof waterproofing — Determination of water vapour transmission properties*

BS EN 13501-5 : 2016 *Fire classification of construction products and building elements — Classification using data from external fire exposure to roofs tests*

BS EN ISO 527-4 : 1997 *Plastics — Determination of tensile properties — Test conditions for isotropic and orthotropic fibre-reinforced plastic composites*

BS EN ISO 14001 : 2015 *Environmental management systems — Requirements with guidance for use*

CEN/TS 1187 : 2012 *Test methods for external fire exposure to roofs*

EAD 030350-00-0402 *Liquid Applied Roof Waterproofing Kits*

EOTA TR-003 : 2004 *Determination of the watertightness*

EOTA TR-004 : 2004 *Determination of the resistance to delamination*

EOTA TR-006 : 2004 *Determination of the resistance to dynamic indentation*

EOTA TR-007 : 2004 *Determination of the resistance to static indentation*

EOTA TR-008 : 2004 *Determination of the resistance to fatigue movement*

EOTA TR-010 : 2004 *Exposure procedure for artificial weathering*

EOTA TR-011 : 2004 *Exposure procedure for accelerated ageing by heat*

EOTA TR-012 : 2004 *Exposure procedure for accelerated ageing by hot water*

EOTA TR-013 : 2004 *Determination of crack-bridging capability*

Conditions

1 This Certificate:

- relates only to the product that is named and described on the front page
- is issued only to the company, firm, organisation or person named on the front page – no other company, firm, organisation or person may hold or claim that this Certificate has been issued to them
- has to be read, considered and used as a whole document – it may be misleading and will be incomplete to be selective
- is copyright of the BBA
- and any matter arising out of or in connection with it or its subject matter (including non-contractual disputes or claims) is governed by and construed in accordance with the law of England and Wales.
- the courts of England and Wales shall have exclusive jurisdiction to settle any matter arising out of or in connection with this Certificate or its subject matter (including non-contractual disputes or claims).

2 Publications, documents, specifications, legislation, regulations, standards and the like referenced in this Certificate are those that were current and/or deemed relevant by the BBA at the date of issue or reissue of this Certificate.

3 This Certificate will be displayed on the BBA website, and the Certificate Holder is entitled to use the Certificate and Certificate logo, provided that the product and its manufacture and/or fabrication, including all related and relevant parts and processes thereof:

- are maintained at or above the levels which have been assessed and found to be satisfactory by the BBA
- continue to be checked as and when deemed appropriate by the BBA under arrangements that it will determine
- are reviewed by the BBA as and when it considers appropriate.

4 The BBA has used due skill, care and diligence in preparing this Certificate, but no warranty is provided.

5 In issuing this Certificate the BBA is not responsible and is excluded from any liability to any company, firm, organisation or person, for any matters arising directly or indirectly from:

- the presence or absence of any patent, intellectual property or similar rights subsisting in the product or any other product
- the right of the Certificate holder to manufacture, supply, install, maintain or market the product
- actual installations of the product, including their nature, design, methods, performance, workmanship and maintenance
- any works and constructions in which the product is installed, including their nature, design, methods, performance, workmanship and maintenance
- any loss or damage, including personal injury, howsoever caused by the product, including its manufacture, supply, installation, use, maintenance and removal
- any claims by the manufacturer relating to UKCA marking and CE marking.

6 Any information relating to the manufacture, supply, installation, use, maintenance and removal of this product which is contained or referred to in this Certificate is the minimum required to be met when the product is manufactured, supplied, installed, used, maintained and removed. It does not purport in any way to restate the requirements of the Health and Safety at Work etc. Act 1974, or of any other statutory, common law or other duty which may exist at the date of issue or reissue of this Certificate; nor is conformity with such information to be taken as satisfying the requirements of the 1974 Act or of any statutory, common law or other duty of care.